



**NOTES:**

- EXCAVATION MUST BE AT LEAST 12" WIDER & LONGER THAN TANK SIZE.
- REINFORCED WITH 12.5 GA. 4" X 4" GALVANIZED WIRE & 3/8" RE-ROD.

LIQUID GALS.	A	B	C	D
	WIDTH	LENGTH	HEIGHT	INVERT
1000	62"	96"	66"	55"
1250	62"	96"	76"	65"



3584 Airline Road  
Muskegon Michigan  
(231) 733-1904

1000-1250 Gal.  
3 Compartment Industrial  
GreaseTrap Precast Concrete

SIZE	DATE	DWG NO.	REV
A	12/02/05	006	
DRAWN BY: B. BUSH		SHEET 1 of 1	