


TOP VIEW



SECTION A-A

NOTES:

1. EXCAVATION MUST BE AT LEAST 12" WIDER & LONGER THAN TANK SIZE
2. REINFORCED WITH 4" x 4" 12.5 GAGE GALVANIZED WIRE & 1/2" RE-ROD.



3584 Airline Road
Muskegon Michigan 49444
(231) 733-1904

1249 gal. Secondary Containment Tank

SIZE A	DATE 12/02/05	DWG NO. 002	REV
DRAWN BY: B. BUSH		SHEET 1 of 2	